





 $\frac{\textbf{ELEVATION}}{X_8'' = 1' \cdot 0''}$

NOTES:

- 1) CONCRETE TO TEST 5,000 PSI AT 28 DAYS.
- 2) DESIGN IN ACCORDANCE WITH AASHTO STANDARD SPECIFICATIONS.
- 3) GEOTECHNICAL DESIGN DATA:
 - 3.1 RETAINED SOIL FRICTION ANGLE 32°.
 - 3.2 FOUNDATION SOIL FRICTION ANGLE 32°.
 - 3.3 SOIL DENSITY: 120 pcf
 - 3.4 ALLOWABLE SERVICE LOAD BEARING PRESSURE: 3,000psf
 - 3.5 COEFFICIENT OF SLIDING FRICTION: 0.5

- 4) REINFORCING STEEL ASTM A615 GRADE 60.
- 5) MATERIALS AND MANUFACTURING SHALL CONFORM TO AASHTO STANDARDS.
- 6) LIFTING AND HANDLING SHALL CONFORM TO OSHA STANDARDS.

WEIGHT
4780 POUNDS

1	
A SK	76 Clove Road alisbury Mills, New York, 12577 ww.arconcrete.com 45-562-0640
	DATE: 9/1/2022
3' CONCRETE HEADWALL	REV.:
	DWN.BY: A&R LLC
CONTRACTOR:	DWG. NO.: HW3FT