


ROOF PLAN MC-101
(75-500 KVA TRANSFORMER COVER)
PICK WEIGHT - 2,700#

ROOF PLAN TYPE 1 - MC-103
(TRANSFORMER COVER)
PICK WEIGHT - 2,700#

NOTE: OPTIONAL H20 ROOF FOR MC-103, 8" THICK.



ROOF PLAN TYPE 2 - MC-102
(75-500 KVA TRANSFORMER COVER)
PICK WEIGHT - 1,200#

GENERAL NOTES:

1. CONCRETE TO TEST 4,000 PSI AT 28 DAYS.
2. REINFORCING STEEL PER ASTM A615, GRADE 60 FOR REBAR AND PER ASTM A185 FOR WELDED WIRE FABRIC(W.W.F.).
3. KNOCKOUT OPENINGS TO BE 4" DEEP, LEAVING A 2" CONCRETE "SKIN".



276 Clove Road
Salisbury Mills, New York, 12577
www.arconcrete.com
845-562-0640

CENTRAL HUDSON GAS & ELECTRIC
PRECAST CONCRETE TRANSFORMER MANHOLE
MC-100
ROOF OPTIONS MC-101, MC-101M, MC-102,
MC-102M & MC-103

DATE: 5/14/2018

REV.: 7/14/2023

DWN.BY: A&R LLC

CONTRACTOR:

DWG. NO.:
AR-CenHudTMH500